


PLACEMENT

Smoke Detectors & Carbon Monoxide Alarms



- 10-year seal carbon monoxide detector(s) & smoke detector(s).
- On every level & sub-level within 10' of bedroom(s) in hallway.
- Including any rooms which may be considered bedrooms.

Hardwired systems **must** remain hardwired & **operable**. It **cannot** be replaced with 10-year seal batteries.



- One fire extinguisher per kitchen(s) may be placed on the kitchen counter. It should not be concealed.
- 10 lb. or less.
- Must have ABC coding on the label.
- Must have a FULL charge! Gauge in the green.

